



Flexible flashing tape over flashing upstand

H3.2 vertical timber batten
*See note

2x 2.8x50mm hot dipped galvanised clout nails in to nog framing @ 600 centres. (SS for Exposure Zone D) (2 nails per batten)

Nu-Wall Fascia - can match wall cladding

MCK 35361
Head flashing fitted as cavity closure (No standard cavity closure required)

NC134P
Pre-slotted base channel. Providing 2000mm² of ventilation per linear meter

3-5mm gap

NC107 + NC109
NC107 & NC109 assembly

NC 204
10g x 16mm csk Tek screw @ 600 centers through anti-crush button

2.8x50mm hot dipped galvanised clout nails @ 600 centres. (SS for Exposure Zone D)

Ripped board

NC203E
Fixing bracket @ 600mm centers

Drained and vented cavity as per E2/AS1

NC226
Impervious barrier between batten & cladding

General note:

- Cladding fixings omitted for clarity

Cavity batten note:

- 20mm timber battens required for all Nu-Wall horizontal board installations
- Batten to have 15° slope for moisture egress
- Battens to all internal, external corners, jambs, and sills to be sized to 18mm to accommodate flashing build up
- 20 and 18mm single castellated battens are available directly from Nu Wall
- Proprietary Nu-Wall AliBat is available as an alternative when a structural non-combustible batten is required

Interactive assembly instructions available

<http://wksp.nz/nw-hoc-sof>



Get WORKINGSPEC from Apple App Store/Google Play



BRANZ Appraised
Appraisal No. 550 [2019]

Nu-Wall cladding horizontal on cavity

Typical Nu-Wall to fascia - soffit - wall (with alternative)

NW-HOC-030.02

Drawn by: Nu-Wall

Date: 20/9/22

Checked by: RL, GT

Scale: 1:2 @ A4

© 2021 copyright in this document is the property of Nu-Wall Aluminium Cladding Limited. All rights reserved. Nu-Wall is a registered trademark of Aluminium Product Brands NZ Limited